| Tom Nizetich, Direc             | tor of Facilities         |                  |   |   |  |  |  |  |  | Date: 5/6/201   |
|---------------------------------|---------------------------|------------------|---|---|--|--|--|--|--|---|
| PROVIDER                        | EXISTING                  | Johnson Controls | CARRIER   | DAIKIN  | LUCIO                                  | LUCIO                                  | LUCIO                                  | LUCIO                                  | LUCIO                                  | ACCO  |
| EQUIPMENT                       | McQuay                    | Chiller Controls |   | Daikin AGZ150E-   | Daikin-Scroll                          | Tran 140-Scroll                        | Trane 150-Scroll                       | Trane 150-Screw                        | Carrier-Screw                          | Daikin AGZ140E-   |
|                                 | ALS150C27-Screw           |                  | Carrier 30XV-Screw  | Scroll  |  |  |  |  |  | Scroll  |
| CAPACITY                        | 137 Ton                   |                  | 160 Ton (140<br>nominal)  | 146 Ton   | 146 Ton                                | 136 Ton                                | 151 Ton                                | 150 Ton                                | 135 Ton                                | 140 Ton   |
| WEIGHT                          | 9,880 lbs                 |                  | 111,175 lbs   | 6,745 lbs   | 6,745 lbs                              | 10,659 lbs                             | 12,114 lbs                             | 9,956 lbs                              | 10,630 lbs                             | 6,600 lbs   |
| COST                            | ,                         | \$36,500         | \$295,000   | \$383,700   | \$301,864                              | \$315,461                              | \$330,350                              | \$339,493                              | \$328,683                              | \$413,328   |
| Proposal Dates                  |                           | 4/17/2019        | 7/26/2017   | 5/17/2017   | 5/18/2017                              | 5/18/2017                              | 5/18/2017                              | 5/18/2017                              | 5/18/2017                              | 4/18/2019   |
| NOTES                           |                           |                  | requested update -<br>Joel is out until<br>4/24   | requested update -<br>Robert to provide<br>week of 4/22                                       | note: cost excludes<br>plans & permits |   |
| LEAD TIME                       |                           |                  | 10-12 weeks   | 10-12 weeks   |  |  |  |  |  | 3-6 weeks - (1)<br>available, (1) in<br>production soon.<br><u>*11-12 weeks</u><br>ordering new |
| REVISED FINAL PRC               | POSAL                     |                  |   |   |  |  |  |  |  |   |
| EQUIPMENT                       | McQuay<br>ALS150C27-Screw | Chiller Controls | Carrier 30XV-Screw  | Daikin AGZ150E-<br>Scroll   | Daikin-Scroll                          | Tran 140-Scroll                        | Trane 150-Scroll                       | Trane 150-Screw                        | Carrier-Screw                          | Daikin AGZ140E-<br>Scroll   |
| CAPACITY                        | 137 Ton                   |                  | 160 Ton (140<br>nominal)  | 146 Ton   | 146 Ton                                | 136 Ton                                | 151 Ton                                | 150 Ton                                | 135 Ton                                | 140 Ton   |
| WEIGHT                          | 9,880 lbs                 |                  | ,<br>111,175 lbs  | 6,745 lbs   | 6,745 lbs                              | 10,659 lbs                             | 12,114 lbs                             | 9,956 lbs                              | 10,630 lbs                             | 6,600 lbs   |
| COST                            |                           | \$36,500         | \$352,795   | \$427,335   | \$301,864                              | \$315,461                              | \$330,350                              | \$339,493                              | \$328,683                              | \$413,328   |
| Add/Alt - include 2<br>weekends |                           |                  | \$27,674  | \$0   |  |  |  |  |  | \$3,400   |
| Subtotal                        |                           |                  | \$380,469   | \$427,335   |  |  |  |  |  | \$416,728   |
| Add/Alt - service               |                           |                  | \$12,240  | \$8,920   |  |  |  |  |  | \$14,352  |
| 2X/Yr                           |                           |                  |   |   |  |  |  |  |  |   |
| TOTAL                           |                           |                  | \$392,709   | \$436,255   |  |  |  |  |  | \$431,080   |
| Proposal Dates                  |                           | 4/17/2019        | 7/26/2017   | 5/17/2017   | 5/18/2017                              | 5/18/2017                              | 5/18/2017                              | 5/18/2017                              | 5/18/2017                              | 4/18/2019   |
| NOTES                           |                           |                  | Physical weight of<br>equipment is not in<br>kind & would<br>require DSA<br>review/approval &<br>extra time | Confirmed w/<br>Robert that he's<br>confident that they<br>can complete the<br>work in 5 days | note: cost excludes<br>plans & permits | note: cost excludes<br>plans & permits | note: cost excludes<br>plans & permits |  | note: cost excludes<br>plans & permits | as of 5/6/19, the (2<br>units are still<br>available  |
| LEAD TIME                       |                           |                  | 10-12 weeks   | 10-12 weeks   |  |  |  |  |  | 3-6 weeks - (1)<br>available, (1) in<br>production soon.<br><u>*11-12 weeks</u><br>ordering new |